

TYPE II A CONVENTIONAL - ORIGINAL & REPAIR

PERMIT NUMBER 3797

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
<u>VANCE</u>	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: <u>BRIAN MANESS</u>			<u>3</u>	<u>4</u>	
APPLICANT: <u>GEORGE SWPHEN</u>		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION:		TYPE OF WASTEWATER SYSTEM			
<u>SPRING VALLEY LAKE RD</u>		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION:		DESIGN FLOW:	<u>360 gpd</u>		
LOT NUMBER: <u>3</u>		LTAR:	<u>0.3</u>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		ABSORPTION AREA:	<u>1200 FT²</u>		
<u>* SEE ATTACHED LAYOUT</u>		TRENCH WIDTH:	<u>3'</u>		
		TRENCH SPACING:	<u>AT LEAST 9' ON CENTERS</u>		
		TOTAL TRENCH LENGTH:	<u>400'</u>		
		NUMBER OF TRENCHES:	<u>2-4</u>		
		GRAVEL DEPTH:	<u>12"</u>		
		TANK SIZE:	<u>1000 GAL</u>		
		CONDITIONS:	<u>18"-24" TRENCH DEPTH</u>		
IMPROVEMENT PERMIT			DATE:		
FOR: <u>BRIAN MANESS</u>			<u>9-17-04</u>		
ISSUED BY: <u>Paul J. Y...</u>					
OPERATION PERMIT			DATE:		
SYSTEM INSTALLED BY:					
ISSUED BY:					

PERMIT VALID FOR
5 YEARS FROM
DATE OF ISSUE