

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
<i>Vance</i>	<i>8202 01037</i>	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
	SR. NO.	BUSINESS ☐	<i>3</i>	<i>3</i>	
		OTHER ☐			
APPLICANT:		WATER SUPPLY	WELL ☒	OTHER ☐	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
<i>Michael O'Donoghue</i>		<i>Private</i>	PUBLIC ☐		
APPLICANT'S NAME & ADDRESS:		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION	REPAIR	
<i>3817 Canby Court</i>					
<i>Frederick, Va 22408</i>					
PROPERTY ADDRESS/LOCATION:		DESIGN FLOW:	<i>360 GPD</i>		
<i>1428 Spring Valley Lane Rd</i>		LTAR:	<i>.36 GPD/ft²</i>	<i>.25 GPD/ft²</i>	
SUBDIVISION:		ABSORPTION AREA:	<i>1200 ft²</i>		
LOT NUMBER:		TRENCH WIDTH:	<i>3'</i>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH DEPTH:	<i>22"</i>	<i>12"</i>	
<i>- Contact HD prior to installation</i>		TRENCH SPACING:	<i>9' O.C.</i>		
<i>- Contractor to estimate & follow contract.</i>		TOTAL TRENCH LENGTH:	<i>300'</i>		
		NUMBER OF TRENCHES:	<i>3</i>		
		GRAVEL DEPTH:	<i>18" installed</i>		
		TANK SIZE:	<i>1000 Gallon</i>		
		PUMP TANK SIZE:	<i>1000 Gallon</i>		
		DISTRIBUTION DEVICE:	<i>Private Mangel</i>		

PERMIT VALID FOR: 5 YEARS
 YES ☒ NO ☐

NO EXPIRATION
 YES ☒ NO ☐

IMPROVEMENT PERMIT

DATE: *8/16/16*

FOR: *Michael O'Donoghue*

ISSUED BY: *Chi Hall*

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# *8577*

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.

(The wastewater system cannot be installed until authorization is signed)

Comments: *ALMA 4X enclosure current panel w/ ALARM - 1/2" - 3/4" taps w/ adjustment valves.*

Date: *8/16/16* Environmental Health Specialist: *Chi Hall*

Construction Authorization Addendum ☒ Yes ☐ No

OPERATION PERMIT

DATE: *8/28/16*

SYSTEM INSTALLED BY: *Gregory Tan Bros*

ISSUED BY: *Chi Hall*

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
 AS REQUIRED BY RULE .1961

Survey of outside property not to scale with site plan

