

* Pump System

PERMIT NUMBER 06734

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Vance	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: 3	
	OWNER: Lake Peninsula LLC	WATER SUPPLY	WELL ☒ PUBLIC ☐	OTHER ☐	
APPLICANT'S ADDRESS:		TYPE OF WASTEWATER SYSTEM	INITIAL <u>Type III</u> INSTALLATION Pump to Conv.	REPAIR Same	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
PROPERTY ADDRESS/LOCATION: 727 Waterstone Ln.		DESIGN FLOW:	360 g/day		
SUBDIVISION: The Peninsula @ Kerr Lake		LTAR:	.3		
LOT NUMBER: 9		ABSORPTION AREA:	1,200 ft ²		PERMIT VALID FOR: 5 YEARS ☒ YES ☐ NO
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH WIDTH:	3'		
* Contact Health Dept. for construction authorization prior to obtaining building permit.		TRENCH DEPTH:	18"		
		TRENCH SPACING:	9' centers		NO EXPIRATION YES ☐ NO ☒
		TOTAL TRENCH LENGTH:	400'		
		NUMBER OF TRENCHES:			
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1,000 g		
		PUMP TANK SIZE:	1,000 g		
		DISTRIBUTION DEVICE:	Pressure Manifold		

IMPROVEMENT PERMIT DATE: 4-20-22

FOR: Mac Singleton, REHS/OMT 6-21-12 4-20-22
ISSUED BY: 4/14/19

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 6734

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments: House must set in designated area

Date: 4-20-22 Environmental Health Specialist: Chris Hall Construction Authorization Addendum ☒ Yes ☐ No

OPERATION PERMIT

DATE:

SYSTEM INSTALLED BY:

ISSUED BY:

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961