

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
 IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
Vance	SER. NO. 1307	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: Hartland		BUSINESS ☐	3		
		OTHER ☐			
APPLICANT: C. Keenan		WATER SUPPLY			
APPLICANT'S ADDRESS: 0209 A 01007		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: 516. 1267 90 Evergreen Place		TYPE OF WASTEWATER SYSTEM			
SUBDIVISION: Cedar Grove		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
LOT NUMBER: 89		DESIGN FLOW:	360		
		LTAR:	.4		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) 		ABSORPTION AREA:	900		
		TRENCH WIDTH:	3		
		TRENCH SPACING:	9		
		TOTAL TRENCH LENGTH:	300		
		NUMBER OF TRENCHES:	4		
		GRAVEL DEPTH:	12" 0		
		TANK SIZE:	1000		
CONDITIONS:		Chamber			
IMPROVEMENT PERMIT				DATE:	
FOR:					
ISSUED BY: W. Vangl PS					9-23-97
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: Greg Harris					
ISSUED BY: W. Vangl					2-10-98

Gregory + Susan Curran

.75