

PERMIT NUMBER **2972**

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY: VANCE	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
	SR NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: 3	
OWNER: RICHARD & JACQUELINE WILLIAMS					
APPLICANT: RICHARD WILLIAMS		WATER SUPPLY			
APPLICANT'S ADDRESS: 923 ORANGE ST. HENRISON		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: 0528 01084 STEWART FARM RD. 363		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: EASTVIEW FARMS		DESIGN FLOW:	360 gpd/day		
LOT NUMBER: 14		LTAR:	0.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		ABSORPTION AREA:	1200 FT²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' ON CENTERS		
		TOTAL TRENCH LENGTH:	400'		
		NUMBER OF TRENCHES:	4-6		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 GAL		
		CONDITIONS:	24" TRENCH DEPTH		
IMPROVEMENT PERMIT FOR: RICHARD & JACQUELINE WILLIAMS ISSUED BY: Paul I. [Signature]				DATE: 4-26-01	
OPERATION PERMIT SYSTEM INSTALLED BY: NORMAN CLIFFORD ISSUED BY: Paul I. [Signature]				DATE: 9-27-01	