

* Repair Permit (Installed with EZ Flow)

PERMIT NUMBER 06602

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT INCLUDING SYSTEM REQUIREMENTS.
Vance	SR NO.	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: Gary Tillotson		BUSINESS ☐	3	2	
APPLICANT'S ADDRESS: 1060 Kelly Rd. Henderson, NC 27537		OTHER ☐	WELL PUBLIC ☒	OTHER ☐	
		WATER SUPPLY	INITIAL INSTALLATION	REPAIR Type II Accepted	THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
PROPERTY ADDRESS/LOCATION: 396 Forest Home Ln.		TYPE OF WASTEWATER SYSTEM	DESIGN FLOW:	360 g/day	
SUBDIVISION: Kerr Lake		LTAR:		.3	
LOT NUMBER: Kerr Lake		ABSORPTION AREA:		900 ft ²	
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH WIDTH:		3' / 6"	
		TRENCH DEPTH:		36"	
		TRENCH SPACING:		9' center	
		TOTAL TRENCH LENGTH:		300'	
		NUMBER OF TRENCHES:		2	
		GRAVEL DEPTH:		NA	
		TANK SIZE:		1,000 g	
		PUMP TANK SIZE:		NA	
	DISTRIBUTION DEVICE:		D-box		

IMPROVEMENT PERMIT

DATE:

FOR:

ISSUED BY:

Mac Shingleton, PE

5-25-11

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT # 06602

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments:

Date: 5-25-11

Environmental Health Specialist:

Mac Shingleton, PE

Construction Authorization Addendum

☐ Yes ☐ No

OPERATION PERMIT

DATE:

SYSTEM INSTALLED BY:

Wilson Enterprise

5-25-11

ISSUED BY:

Mac Shingleton, PE

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961