

PERMIT NUMBER 2291

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
VANCE	0539A01004	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: VENTURES	SIR NO.	BUSINESS ☐	3		
		OTHER ☐			
APPLICANT: SAME		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION:		TYPE OF WASTEWATER SYSTEM			
SOUTHERLAND MILL RD 70 Vintage Lane		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: AMCOCK VILLAGE		DESIGN FLOW:	360 gal/day		
LOT NUMBER: 4		LTAR:	0.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		ABSORPTION AREA:	1200 FT ²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' ON CENTERS		
		TOTAL TRENCH LENGTH:	400' (300')		
		NUMBER OF TRENCHES:	3-5		
		GRAVEL DEPTH:	12" (18")		
		TANK SIZE:	900 GAL		*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
		CONDITIONS:	24" (30" T.D.) TRENCH DEPTH		
IMPROVEMENT PERMIT				DATE:	
FOR: VENTURES				1-4-2000	
ISSUED BY: Paul T. Dunn					
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: RICKY PEARCE				2-9-2000	
ISSUED BY: Paul T. Dunn					