

INSPECTION DETAIL LIST

ID# 096100477501

Location 4708 UZZLE ROAD

Permit # U2012-0348

Permit Date: 05/01/2012

Expire Date

Applicant TODD & KIMBERLY MCDONALD

Phone 919-451-8634

Contractor

Subdivision

Permit Type NEW HOUSE

Project

Est. Cost \$150000

Owner TODD & KIMBERLY MCDONALD

Lot # 7

Entered 05/01/2012

<u>Inspection Name</u>	<u>Description</u>	<u>Scheduled Date</u>	<u>Completed Date</u>	<u>Result</u>	<u>Inspector</u>
------------------------	--------------------	-----------------------	-----------------------	---------------	------------------

FINAL C/O REINSP	03/26/15 CHECK TWO ITEMS		<u>03/26/2015</u>	PASS	SDE
------------------	--------------------------	--	-------------------	------	-----

Requested By:

Requested By Phone #

REINSP FINAL

03/17/15 EXPOSE INSULATION
UNDER SINK
NEED TO MOUNT BOX INSIDE
OF FIREPLACE MAIN ROOM

03/17/2015

FAIL NOTE

Requested By:

Requested By Phone #

FINAL C/O

1-PIPE WATER HEATER RELIEF
VALVE TO WITHIN 6" OFF
FLOOR OR
TO THE OUTSIDE WITH AN AIR
GAP IN THE LINE
2-MECHANICAL ROOM HAS
EXPOSED INSULATION
BETWEEN GARAGE
AND LIVING SPACE, COVER
WITH 1/2" SHEETROCK. CAN
NOT HAVE
DUCTWORK IN A GARAGE, BOX
IN WITH SHEETROCK. INSTALL
DOORS ON MECH. ROOM
3-GARAGE DOOR MOTOR
RECEPTACLE NOT GROUND
FAULT PROTECTED
4-TRIM OUT ALL WINDOWS AND
DOORS
5-INSTALL KITCHEN COUNTER
AND SINK
6-EXPOSED INSULATION AT
RANGE RECEPTACLE
7-INSTALL INTER-SYSTEM
BONDING BLOCK AT SERVICE
8-SEAL AROUND CONDUIT
UNDER METER

08/19/2014

FAIL
NOTES

ALH

Requested By:

Requested By Phone #