

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Barry Johnson / Terry Dowdy Date 3-27-03 S.R. No. 1710
 Location/Address Lobblilly Lane off Lawrence Rd.
 Subdivision/Mobile Home Park Name Willow Creek Lot Size 1.05 acs.
 Permit No. # 3234 Lot No. 31

New System ☒ Repair _____
 House _____ Mobile Home ☒ Business _____
 No. Bedrooms 4 No. People _____ No. Toilets _____
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Nitrification System:

Tank Size 1000 gal.
 Distribution Box ☒ No. Lines 4
 Nitrification Field 1200 Sq. Ft.
 Lines: 1 2 3 4 5 6
 Width 3' 3' 3' 3' _____
 Length 80' 95' 109' 116' _____
 Grade 0" 0" 0" 0" _____
 Stone Depth 12" 12" 12" 12" _____

Layout to be followed by installer:

Improvements Permit By Eddie Yount Installer Leonard O'Bryant
 Certificate of Completion By Eddie Yount Date of Inspection 3-27-03

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

