

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Carlene Fletcher Date 5-4-01 S.R. No. 1123
 Location/Address Robert's Chapel Rd.
 Subdivision/Mobile Home Park Name Fletchers Way Lot Size 4.69
 Permit No. # 3001 Lot No. 6

New System Repair
 House ☒ Mobile Home ☐ Business ☐
 No. Bedrooms 3 No. People 3 No. Toilets 3
 Water Supply: Private ☒ Approved ☐
 Semi-Public ☐ Unapproved ☐
 Public ☐ None ☐

Nitrification System:

Tank Size 1000 gal.
 Distribution Box yes No. Lines 4
 Nitrification Field 1500 Sq. Ft.
 Lines:

1	2	3	4	5	6
Width <u>3'</u>	<u>3'</u>	<u>3'</u>	<u>2'</u>		
Length <u>133'</u>	<u>133'</u>	<u>133'</u>	<u>120'</u>		
Grade <u>1"</u>	<u>1"</u>	<u>1"</u>	<u>0"</u>		
Stone Depth <u>12"</u>	<u>12"</u>	<u>12"</u>	<u>L.D.P.</u>		

Layout to be followed by installer:

* Sketch on back

Improvements Permit By David Cumbee Installer Vernon Dickerson
 Certificate of Completion By David Cumbee Date of Inspection 11-28-01 11-29-01

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

