

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Richard Whaley Date 10-12-95 S.R. No. 1632

Location/Address Cannady Rd - Franklin, NC 27525

Subdivision/Mobile Home Park Name _____ Lot Size 83.5 A

Permit No. # 1389 Lot No. _____

New System ☒ Repair _____

House _____ Mobile Home SW Business _____

No. Bedrooms 2 No. People 2 No. Toilets _____

Water Supply: Private ☒ Approved _____

Semi-Public _____ Unapproved _____

Public _____ None _____

Nitrification System:

Tank Size 900 gal. _____

Distribution Box ☒ No. Lines 2

Nitrification Field 600 Sq. Ft. _____

Lines: 1 2 3 4 5 6

Width 3' 3' _____

Length 104' 103' _____

Grade 0" 1/4" _____

Stone Depth 12" 12" _____

Layout to be followed by installer:

Improvements Permit By Charles R. Nollin Installer Lynnwood Cole

Certificate of Completion By Christopher M. H. H. H. Date of Inspection 10-16-95

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

