

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

0118 Owner or Contractor Dr. Stephen D. Ertischek Date Oct 22⁸⁶ S.R. No. 1514
 Location/Address Route #5 Oxford N.C.
 Subdivision/Mobile Home Park Name _____ Lot Size Farm
 Lot No. _____

New System ☒ Repair _____
 House ☒ Mobile Home _____ Business _____
 No. Bedrooms 3 No. People 3 No. Toilets 3
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Layout to be followed by installer:

Nitrification System:

Tank Size 900 gal.
 Distribution Box yes No. Lines 2
 Nitrification Field 320 960 Sq. Ft.
 Lines: 1 2 3 4 5 6
 Width 36" 36" _____
 Length 150" 170" _____
 Grade 2" 3" _____
 Stone Depth 12" 12" _____

Improvements Permit By Charles B. Noblin Installer Pete Ellington
 Certificate of Completion By Bobby E. Greene Date of Inspection Oct. 22, 1986

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

