

Cole's 2:00

PERMIT NUMBER 3755

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO. <u>1546004118</u>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: <u>David Murphy</u>	SR. NO. <u>Hwy 56 E</u>	RESIDENCE ☒	NUMBER OF BEDROOMS: <u>4</u>	NUMBER OF OCCUPANTS:	
		BUSINESS ☐			
		OTHER ☐			
APPLICANT: <u>Same</u>		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT'S ADDRESS: <u>12705 Scandwood Ct. Raleigh NC 27613</u>		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <u>4502 Hwy 56 E.</u>		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION:		DESIGN FLOW:	<u>4/80 gal/day</u>		
LOT NUMBER:		LTAR:	<u>.3 gal/day/ft²</u>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) <u>* See attached sheet for layout</u> <u>Lines dug level and on contour with trench depth 18"-24"</u> <u>stay 150' from ponds, 100' from wells, and 10' from property lines</u> <u>→</u>		ABSORPTION AREA:	<u>1600 ft²</u>		
		TRENCH WIDTH:	<u>3'</u>		
		TRENCH SPACING:	<u>9' O.C.</u>		
		TOTAL TRENCH LENGTH:	<u>533'</u>		
		NUMBER OF TRENCHES:	<u>4 or 5</u>		
		GRAVEL DEPTH:	<u>12"</u>		
		TANK SIZE:	<u>1000 gal + 17' Box</u>		
		CONDITIONS: *	<u>See Attached to Construct</u>		
IMPROVEMENT PERMIT				DATE:	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
FOR: <u>David Murphy</u>				<u>4-7-03</u>	
ISSUED BY: <u>David Cumba</u>					
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: <u>Cole's Backhoe Service</u>				<u>10-2-03</u>	
ISSUED BY: <u>M.E. Young, RS</u>					

