

#9292

PUMP

PERMIT NUMBER 8102

Zoning #

13512

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Granville	162400923167	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
OWNER: Steven Hayes	SR. NO.	BUSINESS ☐	WELL ☐	OTHER ☐	
APPLICANT'S ADDRESS: 28 Hayes Ct. S. Kenton, Va		OTHER ☐	PUBLIC ☐	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Danfield Ln		WATER SUPPLY	INITIAL INSTALLATION	REPAIR	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
SUBDIVISION: ph IV Silverleaf		TYPE OF WASTEWATER SYSTEM	Type III big	Type III big	
LOT NUMBER: 95		DESIGN FLOW:	3 gpm		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		LTAR:	3 gpm		
		ABSORPTION AREA:	1600 sq ft		PERMIT VALID FOR 5 YEARS YES ☒ NO ☐
		TRENCH WIDTH:	3'		
		TRENCH DEPTH:	30"		
		TRENCH SPACING:	9' o.c.		
		TOTAL TRENCH LENGTH:	420'		NO EXPIRATION YES ☐ NO ☒
		NUMBER OF TRENCHES:	3		
		GRAVEL DEPTH:	Accepted		
		TANK SIZE:	1200 gal		
		PUMP TANK SIZE:	1200 gal		
		DISTRIBUTION DEVICE:	Pressure manifold		

Follow site sketch / design by Consultant

Keep lowest trench 125' from house foundation

Call 919-693-2688 w/ questions

IMPROVEMENT PERMIT

DATE:

12-12-14

FOR:

ISSUED BY:

Steven Hayes
David Cohen

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 8102

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.

(The wastewater system cannot be installed until authorization is signed)

Comments:

Contours flagged in field - trench depth 26" x 30"

Date:

12-12-14

Environmental Health Specialist:

David Cohen

Construction Authorization Addendum

☐ Yes☐ No

OPERATION PERMIT

DATE:

7/17/15

SYSTEM INSTALLED BY:

ISSUED BY:

David Brantley
Walter D. Dwyer

R.E.H.S.

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION

AS REQUIRED BY RULE .1961