

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Louisburg Development Date 10-5-00 S.R. No. 1138
 Location/Address Diamond Hills Rd off Culbreth Rd
 Subdivision/Mobile Home Park Name Cedar Hills Lot Size 1.18 acres
 Permit No. # 2442 Lot No. 2

New System ☒ Repair ☐
 House ☐ Mobile Home ☒ Business ☐
 No. Bedrooms 4 No. People 4 No. Toilets 4
 Water Supply: Private ☒ Approved ☐
 Semi-Public ☐ Unapproved ☐
 Public ☐ None ☐

Layout to be followed by installer:

Nitrification System:

Tank Size 1000 gal.
 Distribution Box ☒ No. Lines 4
 Nitrification Field 1372 Sq. Ft.
 Lines:

1	2	3	4	5	6
Width <u>3'</u>	<u>3'</u>	<u>3'</u>	<u>3'</u>		
Length <u>115'</u>	<u>115'</u>	<u>115'</u>	<u>115'</u>		
Grade <u>0'</u>	<u>0'</u>	<u>0'</u>	<u>0'</u>		
Stone Depth <u>12"</u>	<u>12"</u>	<u>12"</u>	<u>12"</u>		

Improvements Permit By Paul Gower Installer Paul Carrington
 Certificate of Completion By Eddie Yount Date of Inspection 10-5-00

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

← Culbert Rd SR 1138

