



CURRIN TRACT - 70 ACRES

Abbreviated Soil Study for Septic System Suitability Sept, 2023

John R. Davis, Jr. LSS
098900578317 Rueben Hart Road
Granville County, NC

Several hand auger soil borings were taken at various places across this property to determine if the soil is suitable for septic systems. The soil boring locations shown by "green" dots are **usable** for shallow septic systems. Based on these borings, quite a bit of this land between the drains will be usable for septic systems. The "red" dots indicate soil borings that are unsuitable.



8/7/2023, 11:56:16 AM

Flood Zones	County Boundary	Parcel Connectors	Green: Band_2
AE	Hydro	granville_nc_anno	Blue: Band_3
X	Parcels	Satellite View	
Centerlines		Red: Band_1	

1:9,028
0 0.05 0.1 0.2 mi
0 0.1 0.2 0.4 km
NC OneMap, NC Center for Geographic Information and Analysis, NC 911 Board