

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Wynn Construction Date 8-17-06 S.R. No. NC 965
 Location/Address St. Lucy Drive off NC 965
 Subdivision/Mobile Home Park Name Heritage Hall Lot Size _____
 Permit No. # 05917 Lot No. 30R

New System ☒ Repair _____
 House ☒ Mobile Home _____ Business _____
 No. Bedrooms 3 No. People _____ No. Toilets _____
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Nitrification System: _____

septic pressure manifold
 Tank Size 1000 gal. *pump tank 1000*
 Distribution Box ☒ No. Lines 5
 Nitrification Field 1440 Sq. Ft.
 Lines:

1	2	3	4	5	6
3'	3'	3'	3'	3'	
70'	70'	70'	75'	75'	
0"	0"	0"	0"	0"	
7	7	7	7.5	7.5	

 Stone Depth 7 7 7 7.5 7.5

Layout to be followed by installer:

E 2 Flow units

Improvements Permit By Eddie Yount Installer Robert Blackley
 Certificate of Completion By Eddie Yount / MEY Date of Inspection 8-17-06 / 11-2-06

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

EN Flow



NC 985