

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Nancy Gage Date 3-30-04 S.R. No. 1716
 Location/Address Pebblebrook Drive
 Subdivision/Mobile Home Park Name Pebblebrook Lot Size 10 acres
 Permit No. # 3994 Lot No. 5-A

New System ☒ Repair _____
 House ☒ Mobile Home ☒ Business _____
 No. Bedrooms 4 No. People _____ No. Toilets _____
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Nitrification System:

Tank Size 1000 gal.
 Distribution Box ☒ No. Lines 4
 Nitrification Field 1920 Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3</u>	<u>3</u>	<u>3</u>	<u>3</u>		
Length	<u>125'</u>	<u>125'</u>	<u>125'</u>	<u>125'</u>		
Grade	<u>0'</u>	<u>0'</u>	<u>0'</u>	<u>0'</u>		
Stone Depth	<u>20</u>	<u>20</u>	<u>20</u>	<u>20</u>		

in filter unit

Layout to be followed by installer:

Mike Brown

Improvements Permit By David Cumbee Installer Triangle Pump + Tank
 Certificate of Completion By Eddie Yount Date of Inspection 3-30-04

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

