

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Mack Builders Date 7-18-07 S.R. No. 1711
Location/Address Arvida + Antevra off Bruce Warner
Subdivision/Mobile Home Park Name Marshall Landing Lot Size .94 ac.
Permit No. # 06070 Lot No. 14

New System ☒ Repair _____
House ☒ Mobile Home _____ Business _____
No. Bedrooms 4 No. People _____ No. Toilets _____
Water Supply: Private ☒ Approved _____
Semi-Public _____ Unapproved _____
Public _____ None _____

Nitrification System:

Tank Size 1000 gal. No. Lines 3
Distribution Box ☒ No. Lines _____
Nitrification Field 1600 Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3'</u>	<u>3'</u>	<u>3'</u>			
Length	<u>70'65'</u>	<u>80'50'</u>	<u>90'45'</u>			
Grade	<u>0'10"</u>	<u>0'10"</u>	<u>0'10"</u>			

Stone Depth 7'6.5 8'5 9'4.5

EZ Flow units

Layout to be followed by installer:

Improvements Permit By Eddie Yount Installer True Work/David Tr
Certificate of Completion By Eddie Yount Date of Inspection 7-18-07

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

SR. 1711 Bruce Garner Rd

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

Antenna

Arvida

