



OPERATION PERMIT

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford, NC 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 361852 - 1
County ID Number: 182500559229
Evaluated For: NEW

Property Owner: Bobby Sumner

Address: PO Box 1011

Road #:

City: Youngsville

State/Zip: NC/ 27596

Phone #: (919) 422-5713

Township:

Subdivision: Ironwood

Phase: NEW

Lot: 182

Structure: SINGLE FAMILY

of Bedrooms: 3

of People:

Water Supply: NEW WELL

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☐ Yes ☒ No

Design Flow: 360

System Classification/Description: TYPE III G. OTHER
NON-CONV. TRENCH SYSTEMS

Installer: Truework, Inc.

Certification #:

Specific System EZFLOW EZ 1203H-GEO

Installed:

STB: 502

PT:

Septic Tank Date: 06/30/2022

Pump Tank Date: _____

Comments:

serial distribution

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Stiles, Bailey

Bailey Stiles

Date of Issue: 08/09/2022

Owner/Applicant:

Sumner Construction

P-36185.

Permit Number S-25040

W-25040.

Summer Construction

Ironwood - #182

Physical Address: 3610 River Watch Ln Number of Bedrooms 3

TrueWork, Inc.

08/09/2022
Date

Date

08/09/2022
Date

*File #: 361852 - 2
PIN #: 182500559229
Tax Lot #: 182
Tax Block #:

WELL CONSTRUCTION RECORD

Owner: Bobby Sumner
PO Box 1011
Youngsville, NC 27596

1512/2022
10/25/22

Directions

WELL HEAD CONSTRUCTION

Location:

Latitude:

Longitude:

Enclosure	☐ Yes	☐ No	☒ N/A
Enclosure Floor	☐ Yes	☐ No	☒ N/A
Access Port	☐ Yes	☐ No	☒ N/A
Vent:	☒ Yes	☐ No	☐ N/A
Sample Tap	☒ Yes	☐ No	☐ N/A
Back Flow	☒ Yes	☐ No	☐ N/A
Tee (jet)	☐ Yes	☐ No	☒ N/A
Suction Line	☐ Yes	☐ No	☐ N/A
Temporary	☐ Yes	☐ No	☒ N/A
Well ID Plate	☒ Yes	☐ No	☐ N/A
Pump ID Plate	☒ Yes	☐ No	☐ N/A

EHS: Bullock, Will *W.D. 10/25/22*

Issue Date: 10/25/2022

Casing: Depth: 118 Ft. Thickness: In.
Diameter: In. Top of Casing: 12 In.
Material: SDR 21

Grout:		Depth	Material	Method
From	0 To	20 Ft.	BENTONITE	POUR
From	0 To	Ft.	N/A	N/A

* Liner Date: From 0 To Ft.

Grout:		Depth	Material	Method
From	0 To	Ft.	N/A	N/A

Issued by: Bullock, Will

Date of Issue: 08/23/2021

Comments:

Well grout witnessed on 8/25/22 by WTB.
WF/WS done on 10/25/22 by WTB. GW-1
Received.

This well was constructed, repaired or abandoned in compliance with the well permit and in accordance with 15 A NCAC 02C .0100, .0300.
The well owner shall not place potential sources of groundwater contamination closer to the well than the separation distances specified
in 15A NCAC 02C .0100, .0300.