

PLAN

EXISTING 2" WATERLINE TO BE
FILED AND ABANDONED IN PLACE

STA. 43+96.16 PROPOSED
FIRE HYDRANT ASSEMBLY

MAIN STREET/ROCKWELL ROAD (SR. 1430)

END 6" DR 14 C-900 WATER LINE
W/ 6" GATE VALVE, AND BOX

EXISTING 2.5" PVC SANITARY
SEWER FORCE MAIN

APPROXIMATE PROPERTY LINES
TAKEN FROM GRANVILLE COUNTY
GEOGRAPHIC INFORMATION SYSTEM
(TYPICAL)

ROSTER MATTHEW
1822820913118
2505 GEORGE WILSON RD
CROWVILLE

- NOTES:
1. LOCATIONS OF THE EXISTING UTILITIES AS SHOWN ARE APPROXIMATE ONLY. EXACT LOCATIONS ARE TO BE VERIFIED IN THE FIELD BY THE CONTRACTOR.
 2. CONTRACTOR SHALL REMOVE AND REPLACE ROADWAY SIGNS AND MAILBOXES AS NECESSARY TO INSTALL PROPOSED UTILITY LINE. CONTRACTOR SHALL COORDINATE SIGN REMOVAL AND REPLACEMENT WITH THE NCDOT.
 3. CONTRACTOR SHALL COORDINATE WORK IN THE PROXIMITY OF UTILITY POLES WITH THE APPROPRIATE UTILITY COMPANIES.
 4. CONTRACTOR SHALL PLACE A 2" LAYER OF SAND ON ALL ASPHALT OR CONCRETE SURFACES PRIOR TO PLACING EXCAVATED MATERIAL.
 5. CONTRACTOR SHALL CONTACT ALL UTILITY PROVIDERS CONCERNING EXACT LOCATION OF EXISTING LINES PRIOR TO CONSTRUCTION. IF EXISTING UTILITY CABLES ARE ENCOUNTERED IN CONFLICT WITH PROPOSED UTILITY LINE, CONTRACTOR SHALL STRIP OUT EXISTING CABLES, INSTALL PROPOSED UTILITY LINE, & RE-INSTALL EXISTING UTILITY CABLES.
 6. ALL RIGHT OF WAY INFORMATION PROVIDED BY THE NORTH CAROLINA DEPARTMENT OF TRANSPORTATION.
 7. ALL UTILITY LINE INSTALLATIONS SHALL BE A MINIMUM OF 3' OFF THE EDGE OF PAVEMENT UNLESS SHORING MEASURES APPROVED BY NCDOT AND THE ENGINEER ARE UTILIZED.
 8. CONTRACTOR SHALL ADD THRUST BLOCKING AT ALL HORIZONTAL AND VERTICAL ELBOWS AND TEES SEE SHEET C-502

22.01912 TOWN OF STOVALL MAIN ST. - ROCKWELL RD STA 35+00 - 43+99

TOWN
LIMITS

TY -SOLID AS IS

2 CROWN VICTORIA

00 WATER LINE
ALVE, AND BOX

FOR

TOWN OF ST

JOB CROWN

ING ACCP

DOOR SE

ITTED AT

900 TC

500 D

ORE

FILE

1/2" 1"= 30'

1"= 3'