

#  
2454

# GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Dudley Williams Date 5-13-92 S.R. No. 1662  
Location/Address Rt. 3 Oxford, N.C.  
Subdivision/Mobile Home Park Name Stoneridge Lot Size 1.32 AC  
Permit No. # \_\_\_\_\_ Lot No. 4

New System ☒ Repair \_\_\_\_\_  
House ☒ Mobile Home \_\_\_\_\_ Business \_\_\_\_\_  
No. Bedrooms 3 No. People For sale No. Toilets 2 1/2  
Water Supply: Private ☒ Approved \_\_\_\_\_  
Semi-Public \_\_\_\_\_ Unapproved \_\_\_\_\_  
Public \_\_\_\_\_ None \_\_\_\_\_

Nitrification System:  
Tank Size 900 gal.  
Distribution Box yes No. Lines 4  
Nitrification Field 300' - 900' Sq. Ft.  
Lines:      1      2      3      4      5      6  
Width      3'      3'      3'      3'      \_\_\_\_\_  
Length      54'      54'      100'      100'      \_\_\_\_\_  
Grade      1"      1/2"      2"      0"      \_\_\_\_\_  
Stone Depth 12"      12"      12"      12"      \_\_\_\_\_

Layout to be followed by installer:

Improvements Permit By Charles R. Noblin Installer Ricky Pearce  
Certificate of Completion By Charles R. Noblin Date of Inspection 7-7-92

\* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

