

REPAIR

PERMIT NUMBER 3615

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: <u>VANCE</u>	TAX NO. <u>0202 02044</u>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
SR. NO.		RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: <u>3</u>	NUMBER OF OCCUPANTS: <u>4</u>	
OWNER: <u>TIM & BONNIE STRANGE</u>					
APPLICANT: <u>SAME</u>		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	☒ COMMUNITY WELL ☐	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <u>105 LAKE RD.</u>		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: <u>Spring Valley</u>		DESIGN FLOW:		<u>360 gal/day</u>	
LOT NUMBER: <u>24</u>		LTAR:		<u>0.25</u>	
REFERENCE SKETCH (SEE PLAT FOR DETAILS) 		ABSORPTION AREA:		<u>ADD 300-600 FT²</u>	
		TRENCH WIDTH:		<u>3'</u>	
		TRENCH SPACING:		<u>AT LEAST 9' IN CENTER</u>	
		TOTAL TRENCH LENGTH:		<u>100'-200'</u>	
		NUMBER OF TRENCHES:		<u>1-2</u>	
		GRAVEL DEPTH:		<u>12"</u>	
		TANK SIZE:		<u>EXISTING</u>	
		CONDITIONS:		<u>24-36" TRENCH DEPTH</u>	
IMPROVEMENT PERMIT				DATE:	
FOR: <u>TIM & BONNIE STRANGE</u>				<u>5-6-04</u>	
ISSUED BY: <u>Paul L. Don</u>					
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: <u>LIN GOLF</u>				<u>5-12-04</u>	
ISSUED BY: <u>Paul L. Don</u>					