



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: JIMMY CLAYTON

GRANVILLE CO ENVIRONMENTAL HEALTH
PO BOX 367
Oxford, NC 27565

Received

NOV 14 2024

Granville County
Health Department

Name of System:

Haven Homes
994 Browning Place
Youngsville, NC 27596

EIN: 561060453EH

Delivery: NC Courier

Granville County

StarLiMS ID: ES241105-0100

Date Collected: 11/04/2024

Time Collected: 12:20

By: Jimmy Clayton

Date Received: 11/05/2024

Time Received: 08:21

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Well

Sample Type: Raw

GPS No.

Treatment:

Well Permit No.

Comment: No permit # given with sample.

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			11/05/2024
E. coli	Absent			11/05/2024

Report Date: 11/06/2024

Reported By: DNEWBORN

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.