

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

1234

Owner or Contractor Adam & Cheryl Fowler Date 2-11-87 S.R. No. 1710

Location/Address Rt. 1 Oakmoor, N.C.

Subdivision/Mobile Home Park Name Woodstone Lot Size 1/4c ±
Lot No. 24

New System ☒ Repair ☐
House 3 Mobile Home 0 Business 0
No. Bedrooms 3 No. People 4 No. Toilets 2 1/2
Water Supply: Private ☒ Approved ☐
Semi-Public ☐ Unapproved ☐
Public ☐ None ☐

Nitrification System:

Tank Size 900 gal.

Distribution Box yes No. Lines 2

Nitrification Field 240' 1080 Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3'</u>	<u>3'</u>				
Length	<u>120'</u>	<u>70'</u>				
Grade	<u>1 1/2"</u>	<u>2"</u>				
Stone Depth	<u>18"</u>	<u>18"</u>				

Layout to be followed by installer:

Improvements Permit By Charles R. Noblin Installer Joe Frazier

Certificate of Completion By Charles R. Noblin Date of Inspection 3-25-87

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

