



IMPROVEMENT PERMIT

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford, NC 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 415129 - 1
County ID Number: 192600906140
Evaluated For: NEW

PERMIT VALID UNTIL: 07/12/2029

*NOTE TO INSPECTIONS DIVISION: Building Permits cannot be issued with this Improvement Permit.

Applicant: Robert Blackley
Address: 608 Amsterdam Lane
City: Creedmoor
State/Zip: NC 27522
Phone #: home: (919) 418-0312 cell: (919) 418-0312

Property Owner: Chewning Road Properties
Address: 6644 Woodlawn Drive
City: Oxford
State/Zip: NC. 27565
Phone #: home: (919) 418-0312 cell: (919) 418-0312

Property Location & Site Information

Address: 6644 Woodlawn Drive Oxford, NC 27565
Subdivision: Woodlawn Block/Phase: NEW Lot: 35

Directions

Road #:
Structure: SINGLE FAMILY
of Bedrooms: 3
of People:
*Water Supply: NEW WELL

System Specifications

Initial System

Usable Soil Depth:

Design Flow: 360

Soil Application Rate: 0.3000

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System:

25% REDUCTION

Minimum Trench Depth: 20 Inches

Maximum Trench Depth: 24 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

Repair System

Usable Soil Depth:

Soil Application Rate: 0.300

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System: 25% REDUCTION

Minimum Trench Depth: 20 Inches

Maximum Trench Depth: 24 Inches

Pump Required: ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.

*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

Drain lines min. 10' off property lines. Keep any part of septic min. 5' off house. Min. 50' off wells.


CDP File Number: 415129

County ID Number: 192600906140

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (per rule .0301(fa)).

Authorized State Agent:

Bullock, Will



Date of Issue:

07/12/2024

Total Time: (HH:MM)



Hand Drawing



Import Drawing

****Site Plan/Drawing attached.****



Construction Authorization

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford, NC 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number: 415129 - 1
County ID Number: 192600906140
Evaluated For: NEW

PERMIT VALID UNTIL: 07/12/2029

☐ Open Pump System Sheet

Applicant: Robert Blackley
Address: 608 Amsterdam Lane
City: Creedmoor
State/Zip: NC 27522
Phone #: home: (919) 418-0312 cell: (919) 418-0312

Property Owner: Chewning Road Properties
Address: 6644 Woodlawn Drive
City: Oxford
State/Zip: NC, 27565
Phone #: home: (919) 418-0312 cell: (919) 418-0312

Property Location & Site Information

Address/Road #: 6644 Woodlawn Drive Oxford, NC 27565 Subdivision: Woodlawn Phase: NEW Lot: 35

Directions:

Structure: SINGLE FAMILY

of Bedrooms: 3

of People:

*Water Supply: NEW WELL

System Specifications

Usuable Soil Depth:

Design Flow: 360

Soil Application Rate: 0.3000

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System:

25% REDUCTION

Minimum Trench Depth: 20 Inches

Maximum Trench Depth: 24 Inches

Minimum Soil Cover: Inches

Maximum Soil Cover: Inches

*Distribution Type: GRAVITY - PARALLEL (eq. d-box)

Nitrification Field: 900 Sq. ft.

No. Drain Lines: 3

Total Trench Length: 300 ft.

Trench Spacing: 9 - Inches

Trench Width: 3 - Feet

Aggregate Depth: inches

Septic Tank: 1,000 Gallons
Pump Required: ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

Grease Trap: Gallons

Septic Tank Installer
Grade Level Required: ☐ I ☒ II ☐ III ☐ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions:

Drain lines min. 10' off property lines. Keep any part of septic min. 5' off house. Min. 50' off wells.

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.0204(k)(1)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting and repair (per rule .0301(a)).

Authorized State Agent: Bullock, Will

Date of Issue: 07/12/2024

Site Plan/Drawing attached.

Total Time : (HH:MM)

☒ Hand Drawing

☐ Import Drawing

Granville-Vance Dist. Health Department
Environmental Health

Pin _____

Permit Number P-415128

☒ Improvement Permit

3 bdrm.

☒ Construction Authorization

SITE SKETCH

Robert Blackley
Applicants Name


6646 Woodlawn Dr.
Address

Woodlawn 35
Subdivision - Section - Lot


W. B. RENS
Authorized State Agent

7-12-24
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that proper grade is maintained.



To
Channing
R.



Well Construction Permit

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford NC, 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 415129

PIN Number: 192600906140

Tax Lot #: 35

Tax Block #: _____

Evaluated For: _____

PERMIT VALID UNTIL: 07/12/2029

Property Owner: Chewning Road Properties
Address: 6644 Woodlawn Drive
City: Oxford
State/Zip: NC / 27565
Phone #: H: (919) 418-0312 C: (919) 418-0312

Applicant: Robert Blackley
Address: 608 Amsterdam Lane
City: Creedmoor
State/Zip: NC / 27522
Phone #: H: (919) 418-0312 C: (919) 418-0312

Property Location & Site Information

Address/Road #: _____ Subdivision: Woodlawn Phase: _____ Lot: 35
6644 Woodlawn Drive
Oxford NC, 27565
*Proposed use of Well: _____
If Other: _____
Applicant Email: robert.blackley@yahoo.com
Owner Email: robert.blackley@yahoo.com

Directions: _____

Well Contractor Information

Drilling Contractor: _____

Driller Registration: _____

Permit Conditions

*Permit Conditions

Keep proposed well min. 50' off any part of septic (including neighboring lots). Min. 25' off house. Stay out of road right of way. Well driller responsible for maintaining all setbacks.

Well location, construction and protection must meet all state and local regulations and must be inspected and approved by an authorized representative of the Local Health Department. The permit may be revoked at any time for failure to comply with existing regulations. The siting of approved well construction area(s) by the Health Department is to provide protection from the known possible sources of contamination. The approved well area(s) may not be changed without permission from an authorized representative of the Local Health Department. Issuance of this well permit does not guarantee water quality or adequate water production from the well once it is installed or repaired.

*Issued By: Bullock, Will

Authorized State Agent: Robert Blackley

Owner/Applicant: Robert Blackley

*Date of Issue: 07/12/2024

☒ Hand Drawing ☐ Import Drawing

Site Plan/Drawing attached.



Well Construction Permit

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford NC, 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 415129

PIN Number: 192600906140

Tax Lot #: 35

Tax Block #: _____

Evaluated For: _____

PERMIT VALID UNTIL: 07/12/2029