

Incomplete Pump File

PERMIT NUMBER N2

261

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Granville	SR NO. 1159	RESIDENCE ☒	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS:	
OWNER: Thomas Harris		BUSINESS ☐	OTHER ☐		
APPLICANT: Thomas Harris		WATER SUPPLY			
APPLICANT'S ADDRESS: 1724 Sanders Rd		PUBLIC ☐	WELL ☒	OTHER ☐	*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
PROPERTY ADDRESS/LOCATION: Corner of Thal Cury + Deer Run Drive		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION ☒	REPAIR	
SUBDIVISION: Deer Run		DESIGN FLOW:	360 gal/day		
LOT NUMBER: 18 R		LTAR:	.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) See sketch attached. Dig trenches 18"-24" deep on contour (level). Stay at least 5' from house, 10' from property line + 100' from any well. May need pump. Check grade. Call Health Dept.		ABSORPTION AREA:	1200 sq. ft.		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' on center		
		TOTAL TRENCH LENGTH:	400 ft		
		NUMBER OF TRENCHES:	3 or 4		
		GRAVEL DEPTH:	12"		
		TANK SIZE: 900 gal	900 gal		*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
		CONDITIONS:			
IMPROVEMENT PERMIT		DATE:			
FOR: Thomas Harris		7-16-96			
ISSUED BY: M.E. Young					
OPERATION PERMIT		DATE:			
SYSTEM INSTALLED BY:					
ISSUED BY:					

10 2.96 10 3.96
1000

230'

140' 1/2"

137' 1"