

PUMP TO CONVENTIONAL - ORIGINAL & REPAIR

PERMIT GOOD FOR FIVE YEARS PERMIT NUMBER 4073

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: VANUE	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
OWNER: T&W INVESTMENTS	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 4	NUMBER OF OCCUPANTS: ≤ 8	
APPLICANT: WA. CURPIN		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: 198 S. BENJAMIN HARRISON LN		TYPE OF WASTEWATER SYSTEM			*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: SOMERSET		DESIGN FLOW:	480 gal/day		
LOT NUMBER: 19 & 19A		LTAR:	0.25		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) * SEE ATTACHED LAYOUT		ABSORPTION AREA:	1920 FT²		
PERMIT VALID FOR 5 YEARS FROM DATE OF ISSUE		TRENCH WIDTH:	3'		
		TRENCH SPACING:	AT LEAST 9' ON CENTERS		
		TOTAL TRENCH LENGTH:	640'		
		NUMBER OF TRENCHES:	4-5		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 GAL - SEPTIC TANK 1000 GAL - PUMP TANK		
		CONDITIONS:	24" TRENCH DEPTH		
IMPROVEMENT PERMIT				DATE: Updated 7-22-10	PERMIT VALID FOR 5 YEARS FROM DATE OF ISSUE
FOR: T&W INVESTMENTS					
ISSUED BY: Carol L. Dan				7-22-10 mds	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY:					
ISSUED BY:					