

Pump

PERMIT NUMBER 2259

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY: Vance	TAX NO. 0608A01037	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
SR NO.		RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: —	
OWNER: James A Tart					
APPLICANT: Same		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Sat. Pt. Rd 1081 Franklin Ln		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: Timberlake II		DESIGN FLOW:	360		
LOT NUMBER: 68 1-6		LTAR:	.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) Call H.D. for layout when lot cleared		ABSORPTION AREA:	1200²ft		
		TRENCH WIDTH:	3		
		TRENCH SPACING:	9'		
		TOTAL TRENCH LENGTH:	400'		
		NUMBER OF TRENCHES:	4		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 sept tank 1000 gal pump tank		
CONDITIONS:		manifold dist			
IMPROVEMENT PERMIT				DATE:	
FOR: ISSUED BY: Walter P. Dargatzis				12-10-99	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY:					
ISSUED BY:					

