

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 13-52C CONST IMPROVE PERMIT 20000418	DATE: 9854	SIZE: 4A
APPLICANT: LEREW LARRY & MARIE 55 SCRENITY LANE LOUISBURG NC 27549	OWNER: LEREW LARRY	
TELEPHONE: 496-2444		
COMMENT: MODULAR	DESCRIPTION: 5 YEAR ☒	LIFETIME: ☐
LOCATION / DIRECTIONS: SR 1003 Off Sims Bridge Rd ≈ 1/4 mile north of Dukes Rd.		
FEE: 125.00 23265	SIGNATURE OR OWNER OR AUTHORIZED AGENT:	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>
R. HOR <u>✓</u>	SOIL. WET <u>PS</u>	AVAIL. SP <u>S</u>	OTHER <u>✓</u>
MINRL <u>S</u>	OVERALL <u>PS</u>	LTAR <u>40</u>	
#BEDRMS <u>3</u>	GPD <u>3600</u>	DISPOSAL <u>✓</u>	TYPE. SYS <u>Conu</u>
SZ. TANK <u>900</u>	SZ. CHAMB <u>1000</u>	NITRIFI <u>3'x300</u>	TYPE. WAT <u>well</u>
SITE. LOC <u>✓</u>	MAX TRENCH DEP <u>18"</u>	TYP. FAC <u>SED</u>	
REMARKS: <u>Stay 100' from well, 5' from foundation, 10' from property lines, 50' from</u>			

led lines & #1's off Tanks R66 6/2/00



CONTRACTOR: Vernon Dickerson

TANK MANUF: Ellis 900

MANUF DATE: 11-17-99

Pump pumps & Alarm Sounds

*Follow soil scientists flagged layout.



Run drain lines with contour until needed stepdown for serial distribution.

IMPROVEMENT PERMIT DATE: 4/19/00

CONSTRUCTION AUTHORIZATION DATE: 4/19/00

OPERATION PERMIT DATE: 7/21/00

ENV HEALTH SPEC: Dustin Fender

ENV HEALTH SPEC: Dustin Fender

ENV HEALTH SPEC: Dustin Fender