

GRANVILLE VANCE

public health

OPERATION PERMIT

Vance County Health Dept

Environmental Health

115 Charles Rollins Road

Henderson, NC 27536

Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 336031 - 1

County ID Number: 0326 01044

Evaluated For: NEW

Property Owner: Ann Riley

Address: 765 Townsville Landing Rd

Road #:

City: Henderson

State/Zip: NC/ 27537

Phone #: (919) 730-8021

Township:

Subdivision:

Phase : NEW

Lot:

Structure: SINGLE FAMILY

of Bedrooms: 3

of People: 2

Water Supply: NEW WELL

Saprolite System?: ☐ Yes ☒ No

Pump Required?: ☐ Yes ☒ No

Design Flow: 360

System Classification/Description: TYPE II A. CONV SYSTEM
(SINGLE-FAMILY OR 480 GPD OR LESS)

Installer: HARDY CONSTRUCTION

Certification #: 7296

Specific System EZFLOW EZ 1203H-GEO

Installed:

Septic Tank Date: 09/17/2021

STB: 322

Pump Tank Date: _____

PT:

Comments:

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Hedrick, Chris

Date of Issue: 02/01/2022

Owner/Applicant: _____