

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

PERMIT NUMBER

05346

Feb. 9th
11:00-

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Granville	194100309612	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
	SR. NO. 1615	BUSINESS ☐	3	2	
	OWNER: Marvin Wanner	OTHER ☐			
APPLICANT'S ADDRESS: Same		WATER SUPPLY	WELL ☒	OTHER ☐	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
8308 Sleepy Creek Dr Raleigh, NC 27613		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION	REPAIR (Inactive)	
Old Watkins Rd. (Vance County)		DESIGN FLOW:	360 gal/day	Type III g	
PROPERTY ADDRESS/LOCATION: Woody Lane (off Rock Chapel)		LTAR:	.25 gal/day/ft ²		
SUBDIVISION:		ABSORPTION AREA:	1440 ft ²		
LOT NUMBER:		TRENCH WIDTH:	3'		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) Lines dug level and on contour. Keep system mostly in cleared area - Tank & lines 15' from basement foundation. Call 693-2688 if any questions.		TRENCH DEPTH:	24"		
		TRENCH SPACING:	9' o.c.		
		TOTAL TRENCH LENGTH:	480'	360'	
		NUMBER OF TRENCHES:	4-7		
		GRAVEL DEPTH:	12"	4' infiltrators	
		TANK SIZE:	1000 gal		
		PUMP TANK SIZE:			
		DISTRIBUTION DEVICE:	distribution box		PERMIT VALID FOR: 5 YEARS YES ☒ NO ☐
					NO EXPIRATION YES ☐ NO ☒

***** IMPROVEMENT PERMIT DATE: 12-19-05 *****

FOR: Marvin Wanner
ISSUED BY: David Cumber RS.

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 05346

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments: Stay 100' from any well and 10' from property line

Date: 12-19-05 Environmental Health Specialist: David Cumber RS.
Construction Authorization Addendum ☐ Yes ☒ No

OPERATION PERMIT

DATE: 2-9-06

SYSTEM INSTALLED BY: Norman Clifford
ISSUED BY: M.E. Mount RS.

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961

