

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGES FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
Granville Applicant's Name & Address: Builders Group Custom Homes 3204 Heritage Trade Dr. Suite 108	LOT SIZE	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
	2.324	BUSINESS ☐	3	6 max.	
	OTHER ☐	WATER SUPPLY WELL ☒	INITIAL INSTALLATION	REPAIR	
PROPERTY ADDRESS/LOCATION: Oxford Ridge Dr.		TYPE OF WASTEWATER SYSTEM		same	PERMIT VALID FOR: 5 YEARS YES ☒ NO ☐ NO EXPIRATION YES ☐ NO ☒
		DESIGN FLOW:	360 GPD		
SUBDIVISION: Oxford Ridge LOT NUMBER: 21		LTAR:	360 GPD / ft ²		
		ABSORPTION AREA:	1200 ft ² → 900 ft ²		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) - May need to bring in lower d/c to slope, especially for repair. - Stay out of disturbed area		TRENCH WIDTH	3'		
		TRENCH DEPTH:	18" low side	16"	
		TRENCH SPACING:	9' on Center		
		TOTAL TRENCH LENGTH:	300'		
		NUMBER OF TRENCHES:	3		
		GRAVEL / ACCEPTED:			
		TANK SIZE:	1000' Gals		
PUMP TANK SIZE:					
		DISTRIBUTION DEVICE:	1" D Box		

IMPROVEMENT PERMIT

 DATE: 6/24/18

 FOR: Builders Group Custom Homes

 ISSUED BY: Chris Hadd

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 1118

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirement.

(The wastewater system cannot be installed until authorization is signed)

 Comments: Contractor to establish & follow contour. 100' from walks & 10' from property line

 Date: 6/24/18 Environmental Health Specialist: Chris Hadd

 Construction Authorization Addendum ☒ Yes ☐ No

OPERATION PERMIT

 DATE: 2-19 Hank & lines

 SYSTEM INSTALLED BY: Brantley

 ISSUED BY: WLB

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE 1961

