

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Marie Hawkins Date 3-4-03 S.R. No. 1668
 Location/Address 4037 Crestview Lane
 Subdivision/Mobile Home Park Name Antioch Acres Lot Size _____
 Permit No. # 3725 Lot No. 11

New System _____ Repair ☒
 House _____ Mobile Home ☒ Business _____
 No. Bedrooms 4 No. People 2 No. Toilets _____
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Nitrification System:

Tank Size Existing gal.
 Distribution Box New No. Lines 3 new 2 old

Nitrification Field _____ Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3'</u>	<u>3'</u>	<u>3'</u>			
Length	<u>85'</u>	<u>100'</u>	<u>110'</u>			
Grade	<u>0"</u>	<u>1/2"</u>	<u>1/2"</u>			
Stone Depth	<u>12"</u>	<u>12"</u>	<u>12"</u>			

Layout to be followed by installer:

* sketch on back

Improvements Permit By Eddie Yount Installer John Ayscue
 Certificate of Completion By David Cumber Date of Inspection 7-21-03

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

