

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Smart Built Inc. Date 8-4-06 S.R. No. 1711
 Location/Address Anterra Drive
 Subdivision/Mobile Home Park Name Marshall Landing Lot Size _____
 Permit No. # 5979 Lot No. 27

New System ☒ Repair _____
 House ☒ Mobile Home _____ Business _____
 No. Bedrooms 4 No. People _____ No. Toilets _____
 Water Supply: Private ☒ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Nitrification System:

Tank Size 1000 gal.
 Distribution Box yes No. Lines 4
 Nitrification Field 1200 Sq. Ft.
 Lines: 1 2 3 4 5 6
 Width 3' 3' 3' 3' _____
 Length 100' 100' 100' 100' _____
 Grade 0" 1" 0" 1" _____
 Stone Depth E-2 Flow _____

Layout to be followed by installer:

** sketch on back*

Improvements Permit By David Cumba Installer James Madden
 Certificate of Completion By David Cumba Date of Inspection 11-6-07

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

