

1:06

1:21



septic doc 2

Edit

PERMIT NUMBER 1470

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY: <u>Vance</u>	TAX NO. <u>0456 A01003</u>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
SR NO. <u>113</u>	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS <u>4</u>	NUMBER OF OCCUPANTS <u>3</u>		
OWNER <u>Robin Matthews</u>					
APPLICANT: <u>same</u>		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <u>S. Lake Lodge Rd</u> <u>38 Summerfield Ln</u>		TYPE OF WASTEWATER SYSTEM			
SUBDIVISION: <u>Summerfield</u>	DESCRIPTION	INITIAL INSTALLATION	REPAIR		*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGES FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
LOT NUMBER: <u>3</u>	DESIGN FLOW	<u>480</u>	<u>1</u>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) 	LTAR	<u>.4</u>			
	ABSORPTION AREA	<u>1200' x 4</u>			
	TRENCH WIDTH	<u>3</u>			
	TRENCH SPACING	<u>9'</u>			
	TOTAL TRENCH LENGTH	<u>400'</u>			
	NUMBER OF TRENCHES	<u>4 or 5</u>			
GRAVEL DEPTH	<u>12"</u>				
TANK SIZE	<u>1000</u>				
CONDITIONS					
IMPROVEMENT PERMIT		DATE:			
FOR: <u>Robin Matthews</u>	ISSUED BY: <u>William T. Ungles</u>			<u>8-31-98</u>	
OPERATION PERMIT		DATE:			
SYSTEM INSTALLED BY: <u>Bruce Buchanan</u>		ISSUED BY: <u>M.E. Grant RS</u>			<u>12-21-98</u>

More

Share