


* Repair/Replacement

STB-872

8-10-06

PERMIT NUMBER 06038

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Vance	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: 6	
OWNER: Fidelity Bank	APPLICANT'S ADDRESS:	WATER SUPPLY	WELL ☒ PUBLIC ☐	OTHER ☐	
PROPERTY ADDRESS/LOCATION: Warrenton Rd. (beside former Jack & Jill Daycare)		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION	REPAIR Type II Conv.	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
SUBDIVISION:		DESIGN FLOW:		360 g/day	
LOT NUMBER:		ABSORPTION AREA:		.4	
		TRENCH WIDTH:		3'	
		TRENCH DEPTH:		36" max.	
REFERENCE SKETCH (SEE PLAT FOR DETAILS) * Change Driveway in order not to drive over new lines.		TRENCH SPACING:		9' centers	PERMIT VALID FOR: 5 YEARS ☒ YES ☐ NO
		TOTAL TRENCH LENGTH:		300'	
		NUMBER OF TRENCHES:		3	
		GRAVEL DEPTH:		12"	
		TANK SIZE:		1,000 g	
		PUMP TANK SIZE:		NA	
		DISTRIBUTION DEVICE:		D-box	NO EXPIRATION YES ☒ NO ☐

IMPROVEMENT PERMIT

DATE:

FOR:

Fidelity Bank

ISSUED BY:

Mac Shingleton, RS

12-15-06

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 06038

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments:

Date: 12-15-06

Environmental Health Specialist:

Mac Shingleton, RS

Construction Authorization Addendum

☐ Yes ☒ No

OPERATION PERMIT

DATE:

SYSTEM INSTALLED BY:

Pearce Backhoe Service

1-24-07

ISSUED BY:

Mac Shingleton, RS

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION

AS REQUIRED BY RULE .1961