



BACTERIOLOGICAL WATER ANALYSIS REPORT
Wake County Human Services Laboratory
10 Sunnybrook Rd., Raleigh, NC 27610
(919) 250-4437 Certification #37503

Collection Site of Water Sample:

3718 Sapphire Ct

Collection Date: 07/21/2025

Collection Time: 07:00 AM

Collection Point: house

Collected By: Brogan

Lab Number: 25072101-01

Permit:

safeathomeservicesllc@gmail.com

WS-151670-2025

Results:

E. coli	Absent
Total coliform	Absent

Report Date: 07/22/2025

Reported By:

Kimberly Trossman

Kimberly Trossman

Environmental Health Manager

All samples are free of residual chlorine prior to analysis.

Total Coliform is a group of related bacteria that are (with few exceptions) not harmful to humans. Total coliforms are used to determine the adequacy of water treatment and the integrity of the distribution system. If Total Coliform is Present, it is recommended that your well water be re-tested to verify that the result is accurate.

If e. coli (fecal) is Present do not use the water for drinking, cooking, washing dishes, bathing or showering.