PERMIT NUMBER 2057

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY: VANCE	TAX NO. 0586 03014	TYPE OF ESTABLISHMENT		
	SR. NO.	RESIDENCE X BUSINESS ___ OTHER ___	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS: 4
OWNER: CAROLYN E. ROSS				
APPLICANT: (JONATHAN) LANDMARK		WATER SUPPLY		
APPLICANT'S ADDRESS:		PUBLIC ___	WELL X	OTHER ___
PROPERTY ADDRESS/LOCATION: 1855 BULLOCKSVILLE RD		TYPE OF WASTEWATER SYSTEM		
		DESCRIPTION	INITIAL INSTALLATION	REPAIR
SUBDIVISION:		DESIGN FLOW:	360	
LOT NUMBER: 5		LTAR:	0.3	
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		ABSORPTION AREA:	1200 FT²	
		TRENCH WIDTH:	3'	
		TRENCH SPACING:	9' ON CENTERS	
		TOTAL TRENCH LENGTH:	400'	
		NUMBER OF TRENCHES:	4 - 5	
		GRAVEL DEPTH:	12"	
		TANK SIZE:	900 GAL	
		CONDITIONS:	24" TRENCH DEPTH	
IMPROVEMENT PERMIT FOR: LAND MARK ISSUED BY: Paul T. Young			DATE: 8-11-99	
OPERATION PERMIT SYSTEM INSTALLED BY: JOHN AYSCUE ISSUED BY: Paul T. Young			DATE: 1-21-2000	



*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.

*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.

*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.