

Owner or Contractor Blackwell Builders Date 5-31-07 S.R. No. 1705
Location/Address Jordan Circle - next to 3653 on (C)
Subdivision/Mobile Home Park Name Old Crossfield Lot Size _____
Permit No. # 06360 Lot No. 35

New System ✓ Repair
House c Mobile Home Business
No. Bedrooms 4 No. People No. Toilets
Water Supply: Private ✓ Approved
Semi-Public Unapproved
Public None

Nitrification System:

Tank Size 1000 3.1 gal. 1000 gal. P.T

Distribution Box Perisil No. Lines 4

Nitrification Field 1200 Sq. Ft.

Lines:	1	2	3	4	5	6
Width	<u>3'</u>	<u>3'</u>	<u>3'</u>	<u>3'</u>		
Length	<u>90'</u>	<u>100'</u>	<u>100'</u>	<u>110'</u>		
Grade	<u>0"</u>	<u>0"</u>	<u>1"</u>	<u>1 1/2"</u>		
Stone Depth	<u>E-3 Flow</u>					

* Sketch on back:

9-210-07

- Set pressure head at 2'

- check alarm

- everything sealed.

Well & Co. #3454

drilled 8-6-57 SGPM

depth - 500' stretch 40'

Case - 97'

Improvements Permit By David Cumba Installer Blackley Brothers
Certificate of Completion By David Cumba Date of Inspection 8-7-07 / 9-26-07

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

Old Franklin Road

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

