

CONVENTIONAL SYSTEM - ORIGINAL & REPAIR

PERMIT NUMBER 3735

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY: <u>VANCE</u>	TAX NO. <u>0411801006</u>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
OWNER: <u>LESLER & ASSOCIATES, INC.</u> <u>WADDELL HEIRS</u>	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: <u>24</u>	NUMBER OF OCCUPANTS: <u>≤ 6</u>	
APPLICANT: <u>LESLER & ASSOCIATES, INC.</u>		WATER SUPPLY			
APPLICANT'S ADDRESS: <u>228 LESLER LN.</u>		PUBLIC ☒	WELL ☐	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <u>HILLDALE & HILLSIDE</u> <u>32 Valley way</u>		TYPE OF WASTEWATER SYSTEM <u>1/8" DIA</u>			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: <u>WEST HILLS</u>		DESIGN FLOW:	<u>360 gal/day</u>		
LOT NUMBER: <u>6</u>		LTAR:	<u>0.3</u>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) <u>* SEE ATTACHED LAYOUT</u>		ABSORPTION AREA:	<u>CHAMBER</u> <u>1200 FT²</u>		
		TRENCH WIDTH:	<u>3'</u>		
		TRENCH SPACING:	<u>AT LEAST 9" ON CENTER</u>		
		TOTAL TRENCH LENGTH:	<u>CHAMBER</u> <u>40</u>		
		NUMBER OF TRENCHES:	<u>2-3</u>		
		GRAVEL DEPTH:	<u>12"</u>		
		TANK SIZE:	<u>1000 GAL</u>		
		CONDITIONS:	<u>24-3 TRENCH DEPTH</u>		
IMPROVEMENT PERMIT				DATE:	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
FOR: <u>LESLER & ASSOCIATES, INC.</u> ISSUED BY: <u>Paul L. Barr</u>				<u>11-3-03</u>	
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: <u>WADDELL BROS.</u> ISSUED BY: <u>Paul L. Barr</u>				<u>4-22-04</u>	