

* 25% Reduction System

PERMIT NUMBER 06105

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Vance	10425 01028	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
	SR. NO.	BUSINESS ☐	3	2	
	OWNER: Dewey Young	OTHER ☐	WATER SUPPLY	WELL ☒	
APPLICANT'S ADDRESS:		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION	REPAIR	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
581 158 Hwy 158 Bus		DESIGN FLOW:	360 g/day		
11wy. US 158 Bus		LTAR:	.3		
PROPERTY ADDRESS/LOCATION: alvoss from Huntstone		ABSORPTION AREA:	900 ft ²		
SUBDIVISION:		TRENCH WIDTH:	3'		
LOT NUMBER:		TRENCH DEPTH:	* 12"		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH SPACING:	9' centers		
		TOTAL TRENCH LENGTH:	300'		
		NUMBER OF TRENCHES:	4		
		GRAVEL DEPTH:	NA		
		TANK SIZE:	1,000 g		PERMIT VALID FOR: 5 YEARS YES ☒ NO ☐
		PUMP TANK SIZE:	NA		NO EXPIRATION YES ☐ NO ☒
		DISTRIBUTION DEVICE:	D-box		

* Trenches will begin @ 17"-18" and will become shallower. They shall be 12" @ end. Extra soil will be need to provide min. 6" cover. Septic tank will extend above original ground surface.

***** IMPROVEMENT PERMIT DATE: *****

FOR: Dewey Young
ISSUED BY: Mac Shingleton, R8

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 06105

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)


Comments: _____

Date: 8-20-07 Environmental Health Specialist: Mac Shingleton, R8
Construction Authorization Addendum ☐ Yes ☒ No

OPERATION PERMIT DATE: 12/13/07

SYSTEM INSTALLED BY: Perkinson Backhoe
ISSUED BY: Sarah Mather Durham, RSI

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961



STB-392
4-11-07

