

PERMIT NUMBER **2402**

**GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT
IMPROVEMENT AND OPERATION PERMITS**

COUNTY: <i>Granville</i>	TAX NO. <i>087900</i> <i>670970</i>	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
SR NO. <i>1126</i>	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: <i>3</i>	NUMBER OF OCCUPANTS: <i>2</i>		
OWNER: <i>Sallie Jackson</i>					
APPLICANT: <i>Hubert Jackson</i>		WATER SUPPLY			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
APPLICANT'S ADDRESS: <i>208 Hilliboro Rd. Oxford, NC 27565</i>		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION: <i>Range Rd.</i>		TYPE OF WASTEWATER SYSTEM			
		DESCRIPTION	INITIAL ☒ INSTALLATION	REPAIR	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
SUBDIVISION:	DESIGN FLOW:	<i>360 gal/day</i>			
LOT NUMBER:	LTAR:	<i>375</i>			
REFERENCE SKETCH (SEE PLAT FOR DETAILS) <i>See sketch on back. Dig Trenches 18"-24" deep level on contour. Stay at least 5' from house, 10' from property line, + 100' from any well. Do not install or call for inspection in rain.</i>	ABSORPTION AREA:	<i>1320 sq ft.</i>			
	TRENCH WIDTH:	<i>3'</i>			
	TRENCH SPACING:	<i>9' on center</i>			
	TOTAL TRENCH LENGTH:	<i>440 ft.</i>			
	NUMBER OF TRENCHES:	<i>3.5</i>			
	GRAVEL DEPTH:	<i>12"</i>			
	TANK SIZE:	<i>1000 gal</i>			
	CONDITIONS:				
IMPROVEMENT PERMIT			DATE:		
FOR: <i>Sallie Jackson / Hubert Jackson</i>			<i>3-27-00</i>		
ISSUED BY: <i>David Cumbee</i>					
OPERATION PERMIT			DATE:		
SYSTEM INSTALLED BY: <i>Cole's Backhoe Service</i>			<i>11-1-00</i>		
ISSUED BY: <i>David Cumbee</i>					

Range Rd

→ To Stern

