

*File #: 405671 - 2
PIN #: 182400696528
Tax Lot #: 4
Tax Block #:

WELL CONSTRUCTION RECORD

Owner: Keith Building
3638 Wild Orchid CT
Wake Forest, NC 27587

Directions

New forest 4

WELL HEAD CONSTRUCTION

Location: 3638 Wild Orchid CT
Wake Forest NC, 27587

Latitude:

Longitude:

Enclosure	☐ Yes	☐ No	☒ N/A
Enclosure Floor	☐ Yes	☐ No	☒ N/A
Access Port	☐ Yes	☐ No	☒ N/A
Vent:	☒ Yes	☐ No	☐ N/A
Sample Tap	☒ Yes	☐ No	☐ N/A
Back Flow	☒ Yes	☐ No	☐ N/A
Tee (jet)	☐ Yes	☐ No	☒ N/A
Suction Line	☐ Yes	☐ No	☐ N/A
Temporary	☐ Yes	☐ No	☒ N/A
Well ID Plate	☒ Yes	☐ No	☐ N/A
Pump ID Plate	☒ Yes	☐ No	☐ N/A

EHS: Bullock, Will

Issue Date: 04/22/2025

Drilling Contractor: Jerry Ball
Driller Registration:
Date Drilled: 09/20/2024
Use of Well: SINGLE FAMILY
Total Depth: 180 Ft.
Static Water Level: 12 Ft.
Replacement Well: NO
Yield: 6 gpm
Water Zone: 1) 0 Ft. 2) Ft.
3) Ft. 4) Ft.
Disinfection Type: GRANULAR Amount:

Casing: Depth: 107 Ft. Thickness: In. Comments:
Diameter: 6 In. Top of Casing: 12 In.
Material: SDR 21

Grout:

From	Depth	To	Ft.	Material	Method
From	0	To	20	BENTONITE	POUR
From	0	To	Ft.	N/A	N/A

* Liner Date: From 0 To Ft.

Grout:


From	Depth	To	Ft.	Material	Method
From	0	To	Ft.	N/A	N/A

Issued by: Bullock, Will

Date of Issue: 02/15/2024

Well drilled on 9/20/24. WF done at time of
SF on 4/22/25. GW-1 Received.

This well was constructed, repaired or abandoned in compliance with the well permit and in accordance with 15A NCAC 02C .0100, .0300.
The well owner shall not place potential sources of groundwater contamination closer to the well than the separation distances specified
in 15A NCAC 02C .0100, .0300.



OPERATION PERMIT

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford, NC 27565

Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 405671 - 1

County ID Number: 182400696528

Evaluated For: NEW

Property Owner: Keith Building
Owner Address: 3638 Wild Orchid CT

City: Wake Forest
State/Zip: NC/ 27587
Phone #: (919) 427-2291 (919) 427-2291
Address: 3638 Wild Orchid CT
Wake Forest, NC 27587

Road #:
Township:
Subdivision: New Forest
Phase : NEW Lot: 4

Structure: SINGLE FAMILY
of Bedrooms:
of People:
Water Supply: NEW WELL
Saprolite System?: ☐ Yes ☒ No
Pump Required?: ☐ Yes ☒ No
Design Flow: 360
System Classification/Description: TYPE III G. OTHER
NON-CONV. TRENCH SYSTEMS

Installer: Blackley Bros

Certification #: 1935

Specific System EZFLOW EZ 1203H-GEO

Installed:

Septic Tank Date: 01/27/2025

STB: 858

Pump Tank Date: _____

PT:

Comments: Installed 5-60' lines (EZ Flow). Put in berm to divert water away from system.

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1301.

II. Monitoring: As required by Rule .1301.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other: Installed 5-60' lines (EZ Flow). Put in berm to divert water away from system.

Authorized State Agent: Bullock, Will

Date of Issue: 04/22/2025

Owner/Applicant:

Keith building