

Soil Study for Septic System Suitability
John R. Davis, Jr. LSS
1039 Heather Lane Granville County, NC

Feb 2, 2022



The soil area shown in "Orange" is **usable** for gravelless septic trenches with a soil loading rate of 0.3 gpd/sqft. The soil consists of a sandy loam over clay subsoil with depths greater than 36 inches. A single family dwelling generally requires about 10,000 square feet of usable soil for a septic system and repair area. This area is approx. 14,600 square feet. The stormwater BMP may be drained to remove the standing water on this lot. A potential well site shown along the proposed drive.

