

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor Harold Mitchell Date 3-24-00 S.R. No. May 96
 Location/Address Land Mark Dr. (off Hwy 96)
 Subdivision/Mobile Home Park Name Mitchell Acres Lot Size _____
 Permit No. # 2400 Lot No. 4b

New System _____ Repair _____
 Use _____ Mobile Home _____ Business _____
 No. Bedrooms 3 No. People _____ No. Toilets _____
 Water Supply: Private _____ Approved _____
 Semi-Public _____ Unapproved _____
 Public _____ None _____

Sanitization System: _____
 Tank Size 1000 gal.
 Distribution Box yes No. Lines _____
 Sanitization Field _____ Sq. Ft. _____
 Lines: _____
 Width 3' 3' 3' 3' 3' 3'
 Length 87' 92' 90' 82' _____
 Grade 0" 0" 0" 0" _____
 One Depth 12" 12" 12" 12" _____

Layout to be followed by installer:
* Sketch of system on back

Improvements Permit By M.E. Young Installer Blackley Bros.
 Certificate of Completion By David Cumbe Date of Inspection 6-22-00

Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

* Not to scale

