



OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 450279 - 1

County ID Number:

Evaluated For: NEW

Property Owner: Chamberlain Homes
Owner Address: 120 A N Salem St

City: Apex
State/Zip: NC/ 27502
Phone #:
Address: 70 Livingston Lane
Spring Hope, NC 27882

Road #:
Township:
Subdivision: Tantallon
Phase: NEW Lot: 9

Structure: SINGLE FAMILY
of Bedrooms: 3
of People: 4
Water Supply: NEW WELL
Saprolite System?: ☐ Yes ☒ No
Pump Required?: ☐ Yes ☒ No
Design Flow: 360
System Classification/Description: TYPE III G. OTHER
NON-CONV. TRENCH SYSTEMS

Installer: DBS

Certification #:

Specific System EZFLOW EZ 1203H-GEO
Installed:

Septic Tank Date: _____

STB: 1000 DB-1000

Pump Tank Date: _____

PT:

Comments:

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1301.

II. Monitoring: As required by Rule .1301.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Bendel, Joel

Date of Issue: 06/27/2025

Owner/Applicant: _____

