



IMPROVEMENT PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone: _____

For Office Use Only

*CDP File Number 384760 - 1

County ID Number: _____

Evaluated For: NEW

PERMIT VALID UNTIL: 12/14/2027

***NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: GREG POLAND

Address: P.O. BOX 19

City: BUNN

State/Zip: NC 27549

Phone #: _____

Property Owner: LAKE ROYALE PROPERTY OWNERS

Address: 9022 LAKE ROYALE

City: LOUISBURG

State/Zip: 27549

Phone #: _____

Property Location & Site Information

Address: 136 CREEK DR LOUISBURG,
NC 27549

Subdivision: LOT ROYALE

Block/Phase: NEW

Lot: _____

Road #: _____

Directions

136 CREEK DR

Structure: OTHER

of Bedrooms: 2

of People: 2

*Water Supply: N/A

System Specifications

Initial System

*Site Classification:

Design Flow: 240

Soil Application Rate: 0.3500

*System Classification/Description:

TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS)

*Proposed System:

25% REDUCTION

Minimum Trench Depth: _____ Inches

Maximum Trench Depth: 20 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: _____ Gallons

Repair System Required: ☐ Yes ☐ No ☐ No, but has Available Space

* 15A NCAC 18A. 1945 * Repair Area Exempt

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department

*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (1938(h)).

Authorized State Agent: _____

Bendel, Joel

Date of Issue: _____

12/14/2022

Total Time: (HH:MM)

☐ Hand Drawing

☐ Import Drawing

Site Plan/Drawing attached.



Construction Authorization

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone: _____

For Office Use Only

*CDP File Number: 384760 - 1

County ID Number: _____

Evaluated For: NEW

PERMIT VALID UNTIL: 12/14/2027

☐ Open Pump System Sheet

Applicant: GREG POLAND

Address: P.O. BOX 19

City: BUNN

State/Zip: NC 27549

Phone #: _____

Property Owner: LAKE ROYALE PROPERTY OWNERS

Address: 9022 LAKE ROYALE

City: LOUISBURG

State/Zip: 27549

Phone #: _____

Property Location & Site Information

Address/Road #: 136 CREEK DR LOUISBURG, NC 27549 Subdivision: LOT ROYALE Phase: NEW Lot: _____

Directions:

Structure: OTHER 136 CREEK DR

of Bedrooms: 2

of People: 2

*Water Supply: _____

System Specifications

*Site Classification: _____ Minimum Trench Depth: _____ Inches

Design Flow: 240

Maximum Trench Depth: 20 Inches

Soil Application Rate: 0.3500

Minimum Soil Cover: _____ Inches

*System Classification/Description:

TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS)

Maximum Soil Cover: _____ Inches

*Proposed System:

25% REDUCTION

*Distribution Type: N/A

Nitrification Field: _____ Sq. ft.

Septic Tank: 1,000 Gallons

No. Drain Lines: _____

Pump Required: ☐ Yes ☒ No ☐ May Be Required

Total Trench Length: 150 ft.

☐ Inches O.C.

Pump Tank: _____ Gallons

☒ Feet O.C.

Trench Spacing: _____ - 9

☐ Inches

Grease Trap: _____ Gallons

Trench Width: _____ - 3

☒ Feet

Aggregate Depth: _____ inches

Septic Tank Installer

Grade Level Required: ☐ I ☐ II ☐ III ☐ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions:

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.1937(g)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting

Authorized State Agent: Bendel, Joel

Date of Issue: 12/14/2022

☐ Hand Drawing

☐ Import Drawing

Site Plan/Drawing attached.

Total Time : (HH:MM) _____



File # 384760 PIN# _____
Property Address: 136 Creek Dr.
Applicant or Owner Name: Greg Poland

Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

☒ Septic Improvement Permit ☒ Septic Construction Authorization (CA) ☐ CA Reissue** ☐ As Built
☐ Well Construction Authorization ☐ Additional Diagram/Specifications Attached

Diagram Date**: 12-14-22 EHS: Joel Bendel

**Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. Septic Operations Permits will be issued after installation is approved, all permits conditions are met, and any outstanding fees are paid. Well Certificate of Completion will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1000 Pump Tank N/A Drainfield 3'x150' Type System Acc Max Trench Depth 20"

Septic Contractor _____ Septic/Pump tank dates _____ Pump fee? ☒ YES ☐ NO pd _____

Well Contractor _____ Well Grout date: _____

* EHS would like to meet installer onsite before install

→ Tight Lot

