

FRANKLIN COUNTY HEALTH DEPARTMENT


PERMIT NUMBER: 126800 CONST IMPROVE PERMIT	DATE: 05.11.99	31787	SIZE: 1.87A
APPLICANT: BAXLEY DEVELOPERS LLC 3010-K WALNUT CREEK PKWAY RALEIGH NC 27606		OWNER: EVANS RD ASSOC	
TELEPHONE: COMMENT: 618-6282		DESCRIPTION: 5 YEAR ☐	LIFETIME: ☐
LOCATION / DIRECTIONS:			
FEE: W CASTLE #21 125.00 11733		SIGNATURE OR OWNER OR AUTHORIZED AGENT:	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>S</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>
R. HOR <u>S</u>	SOIL. WET <u>S</u>	AVAIL. SP <u>3</u>	OTHER <u> </u>
MINRL <u>PS</u>	OVERALL <u>PS</u>	LTAR <u>35</u>	
#BEDRMS <u>3</u>	GPD <u>3600</u>	DISPOSAL <u>N</u>	TYPE. SYS <u>Can</u>
SZ. TANK <u>1000</u>	SZ. CHAMB <u> </u>	NITRIFI <u>3'x350'</u>	TYPE. WAT <u>Pd</u>
SITE. LOC <u> </u>	MAX TRENCH DEP <u>21"</u>	TYP. FAC <u>SFD</u>	

REMARKS: Follow contour, 10' from wells & 10' from prop lines.

Ellis 1000
STB 789
5-11-99
Zabel filter



No STEPPED down!

Chris D. [Signature]