


PERMIT NUMBER 2700

GRANVILLE - VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENT			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
YANCE	0441C-03001				
	SR NO.	RESIDENCE ☒	NUMBER OF BEDROOMS:	NUMBER OF OCCUPANTS:	
		BUSINESS ☐	3	≤ 6	
OWNER: HomeBoys		OTHER ☐			
APPLICANT: T. N. BRIDGES		WATER SUPPLY			
APPLICANT'S ADDRESS:		PUBLIC ☐	WELL ☒	OTHER ☐	
PROPERTY ADDRESS/LOCATION:		TYPE OF WASTEWATER SYSTEM			*THE IMPROVEMENTS PERMIT MUST BE ATTACHED TO A CONSTRUCTION AUTHORIZATION BEFORE OBTAINING BUILDING PERMIT OR OTHER CONSTRUCTION PERMITS AND BEFORE A WASTEWATER SYSTEM IS INSTALLED.
// FERN LN. & MARIOLA		DESCRIPTION	INITIAL INSTALLATION	REPAIR	
SUBDIVISION: SPRING FOREST		DESIGN FLOW:	360 gal/day		
LOT NUMBER: 114		LTAR:	0.3		
REFERENCE SKETCH (SEE PLAT FOR DETAILS) * NEED TO CLEAR WOOD		ABSORPTION AREA:	1200 FT ²		
		TRENCH WIDTH:	3'		
		TRENCH SPACING:	9' ON CENTERS		
		TOTAL TRENCH LENGTH:	400'		
		NUMBER OF TRENCHES:	3-5		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	900 GAL		
		CONDITIONS:	24" TRENCH DEPTH		
IMPROVEMENT PERMIT				DATE:	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USE CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
FOR: HomeBoys				9-27-00	
ISSUED BY: Paul C. Lane					
OPERATION PERMIT				DATE:	
SYSTEM INSTALLED BY: Tom Henderson				11-29-00	
ISSUED BY: Paul T. Lane					